




**MUNICIPAL CORPORATION OF DELHI
OFFICE OF THE DEPUTY HEALTH OFFICER
PUBLIC HEALTH DEPARTMENT
GREEN PARK, AURBINDO MARG,
NEW DELHI-110016**



NO. DHO/SZ/MCD/2026/D-259.

Dated: 23.05.2026

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by Sh. Krishan Kumar Gupta, Public Health Inspector from Public Health Department, South Zone inspected of Tagore International School located at Paschimi Marg, Vasant Vihar, New Delhi - 110057 found that the School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus.

The above certificate is valid for one year from date of issue.

If Building Department or any other Government Agency takes actions against u/a constructions or any dispute, then the Health Certificate will be stand cancelled/ revoked without any further intimation in this regard.

[Handwritten signature]

**Deputy Health Officer
South Zone
Dy. Health Officer
South Zone MCD**

Copy to: -

The Principal

Tagore International School
Paschimi Marg, Vasant Vihar,
New Delhi - 110057.

- Office Copy



ITS TESTING LABORATORY PRIVATE LIMITED

Laboratory: A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar - 201305, (U.P.)
(An ISO 9001: 2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)
Website: www.itslab.in, Email: itrlclab@gmail.com, info@itslab.in, contact@itslab.in
+91 9911659800, 9305780312, 09958849764



Doc. No. – ITS/7.8-01, Page No. – 1 of 1

TEST REPORT

Water Sample Analysis

Report Code: W-110526-52

Issue Date 15/05/2026

Issued To: M/S. TAGORE INTERNATIONAL SCHOOL
PASCHIMI MARG, VASANT VIHAR, NEW DELHI-110057

Sample Description : Delhi Jal Board Water Sample
Sample Drawn On : 11/05/2026
Sample Drawn By : Mr. K.K Sharma (ITS LAB Representative)
Sampling Plan & Procedure : IS:17614 (Part-1):2021
Sample Quantity : 2.0 Liter in Pet Bottle & 200 ml Glass Sterilized Bottle
Weather Condition : Clear
Sample Received On : 11/05/2026
Analysis Duration : 11/05/2026 To 15/05/2026
Standard limits : As per IS: 10500:2012 Drinking water second Revision on date 01.05.2015

ANALYSIS TEST RESULTS

Chemical Analysis					
S. No.	Parameter	Test Method	Results	Requirement (Acceptable Limit)	Permissible Limit in absence of alternate source
1.	pH Value @ 25°C	IS:3025(Part-11)	7.38	6.5 – 8.5	-
2.	Colour (Hazen)	IS:3025(Part-04)	<5.0	5	15
3.	Odour	IS:3025(Part-05)	Agreeable	Agreeable	Agreeable
4.	Taste	IS:3025(Part-7 & 8)	Agreeable	Agreeable	Agreeable
5.	Turbidity (NTU)	IS:3025(Part-10)	<1.0	1	5
6.	Total Hardness (as CaCO ₃) (mg/l)	IS:3025(Part-21)	164	200	600
7.	Chloride(as Cl) (mg/l)	IS:3025(Part-32)	32.8	250	1000
8.	Calcium (as Ca) (mg/l)	IS:3025(Part-40)	4.4	75	200
9.	Total Iron (as Fe) (mg/l)	IS:3025(Part-53)	0.102	1.0	-
10.	Nitrate (as NO ₃) (mg/l)	IS:3025(Part-34)	5.32	45	No Relaxation
11.	Total Dissolved Solids (TDS) (mg/l)	IS:3025(Part-16)	458	500	2000
12.	Alkalinity (as CaCO ₃) (mg/l)	IS:3025(Part-23)	134	200	600
13.	Fluoride (as F) (mg/l)	IS:3025(Part-60)	0.28	1.0	1.5
14.	Sulphate (as SO ₄) (mg/l)	IS:3025(Part-24)	18.2	200	400
15.	Magnesium (as Mg) (mg/l)	IS:3025(Part-46)	19.92	30	100

Microbiological Analysis

RESULTS

S. No.	Parameter	Test Method	Results	Required as per IS-10500:2012
1.	Escherichia coli (cfu/100ml)	IS-15185:2016	Absent	Absent/100ml
2.	Coliform Bacteria (cfu/100ml)	IS-15185:2016	Absent	Absent/100ml

Remarks: Based on above tested parameter, Water sample meets as per IS-10500:2012 in specification.

Note: - Report shall not be produce except in full without approval of the laboratory.

Reviewed by
(Microbiologist)



Authorized Signatory



End of Report

Terms & Conditions :

1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability of our laboratory is limited to invoiced amount.